CHESTERFIELD COUNTY

CHESTERFIELD COUNTY

DINWIDDIE COUNTY

PRINCE GEORGE COUNTY

POCAHONTAS

APPOMATTOX RIVER

BLANDFORD

HIGHLAND TERRACE

BATTERSEA

WEST END PARK

MT. AIRY

SPOTSWOOD HEIGHTS

CENTRAL PARK

Strawberry Island

Battersea Canal

Flea Island

Swans Island

Two miles to intake and 1,500 G.P.M. electrically driven centrifugal pumps, 200 ft. head.

60,000 Gallon tank, elevation 220

Pumping Station
New 1,500 G.P.M. high service pump.
All pumping to high service and low service done from this station, night and day shifts.

Pumphouse, one 600 gpm centrifugal pump held in reserve.

Export Leaf Tobacco Co.
Cockade City Sheds

NEW DISTRIBUTING RESERVOIR
Elevation 163
Capacity 3,000,000 gallons.

To Walnut Hill tank. Elevation 219. Capacity 30,600 gallons.

To Tobacco Shed

Diverting Dam

Old Distributing Reservoirs (not in use)

60,000 Gal. Tank El. 210.

Coagulation Basin

Impounding Reservoirs

KEY

- Water mains.
- Hydrants.
- Valves.
- Fire Department Stations.
- Fire Alarm Boxes.
- Limit of Fire Service.

CORRECTIONS

May 19, 1914 — Information from City Engineer.
Jan. 15, 1917 — " " " "

PETERSBURG
VIRGINIA.

Map showing location and size of water mains, location of hydrants, valves, fire department stations and fire alarm boxes.

from

Electrical and Inspection Department,

South-Eastern Underwriters Association,

ATLANTA, GEORGIA.

(Compiled from maps furnished by city water works and from other data on file)

W.D.C., Ch. Insp. Oct. 2, 1912.

Scale of feet.